

SCI Smithfield Material needed to upgrade Cemline Hot water Storage Tanks

(7) Centrol 2 Water Heater Controllers 02-160-200

(7) Centrol 8" Temp Sensors 02-160-139

(7) Centrol 6" Temp Sensors 02-160-140

(8) Siemens 1-1/2" Valves. Cemline Part Number 03-011-315

(8) Cemline replacement Tube Bundles Cemline Part Number 648A-SP

To include copper lining between the bolt tube sheet, U bend coil, 3/4" O.D. X 19 BWG Copper tubes, Fiber Gaskets. The bundle is a 6" diameter and a 48" Length.

(8) 6" X 12" Stainless Steel Flanged Spool Piece 95-095-000

(8) 6" Garlock 5500 Ring Gaskets 04-005-075

(8) 6" Cast Iron 2 Pass Coil Head with 2" Connections 04-003-017

(8) Hours labor with representative to oversee and supervise our staff with the initial upgrade of two units that are side by side.

SCI Smithfield is looking for a competitive bid on the above listed items to upgrade our existing Hot water storage tanks so that they are capable of producing more Hot water Gallons per minute and to replace all the safety controls to include sensors, valves, controllers, etc. The existing Hot water storage tanks are manufactured by Cemline Corporation 808 Freeport Road, Cheswick, PA 15024.

This bid should also include (8) hours for one trained and experienced staff member from your company to spend a day with our facility to oversee the installation and upgrade of one set of these units. This is to ensure that the upgrade is done properly. This bid will include the above listed parts and quantities as well as (8) hours labor with one trained and experienced staff member from your company as well as shipping of the equipment to our facility at 1120 Pike Street, Huntingdon, PA 16652.

Existing Hot water storage tank model number is V300SWH630 (300 Gallon) See Picture of name plate below.

