

DIMENSIONS: PAC-MKA30BC AND PAC-MKA50BC BRANCH BOXES






PAC-MKA30BC

Unit: mm <in>

SUSPENSION BOLT : W3/8(M10)

REFRIGERANT PIPE FLARED CONNECTION

	A	B	C		TO OUTDOOR UNIT
LIQUID PIPE	1/4F	1/4F	1/4F		3/8F
GAS PIPE	3/8F	3/8F	3/8F		5/8F








PAC-MKA50BC

Unit: mm <in>

SUSPENSION BOLT : W3/8(M10)


REFRIGERANT PIPE FLARED CONNECTION

	A	B	C	D	E	TO OUTDOOR UNIT
LIQUID PIPE	1/4F	1/4F	1/4F	1/4F	1/4F	3/8F
GAS PIPE	3/8F	3/8F	3/8F	3/8F	1/2F	5/8F



DIMENSIONS: MXZ-8C48NA

Unit: mm <in>



4 PIPING-WIRING DIRECTIONS
Piping and wiring connections can be made from 4 directions: FRONT, Right, Rear and Below.

3 FOUNDATION BOLTS
Please secure the unit firmly with 4 foundation (M10×50) bolts. Bolt and nuts must be purchased locally.


2 SERVICE SPACE
Dimensions of space needed for service access are shown in the below diagram.

1 FREE SPACE (Around the unit)
The clearance below shows basic example. Dimension of particular unit are given in the installation manuals etc.

Example of Notes

- ① Refrigerant GAS pipe connection (FLARE) (L or R (Left))
- ② Refrigerant GAS pipe connection (FLARE) (R or L (Right))
- ③ Indication of STOP VALVE connection location.

Piping Knockout Hole Details



1340 Satellite Boulevard, Suwanee, GA 30024
Toll Free: 800-433-4822 www.mehvac.com

