



Gannett Fleming
ENGINEERS AND PLANNERS

PROJECT/LOCATION PAANG @ HIA SME BLDG

GEOLOGIST/ENGINEER DAN STARE

EXCAVATION CONTRACTOR PA ANG

TEST PIT LOG

OPERATOR

TEST PIT NO. TP-2

EXCAVATION EQUIPMENT RUBBER-TIRED HOE

PROJECT NO.

PHOTOGRAPHIC LOG YES NO

DATE STARTED 5-9-02

SURFACE ELEVATION 296

DATE FINISHED 5-9-02

GROUNDWATER OBSERVATIONS (Date, Time, Level) 9.5' @-Hour

| DEPTH | SAMPLE NO. & TYPE | DESCRIPTION OF MATERIALS (Density, Consistency or Rock Hardness; Color, Classification, etc. ...) | USCS | PID FID | REMARKS |
|-------|-------------------|--|------|---------|--|
| 1 | | 0.0'-1.0': BROWN SANDY SILT w/ ORGANICS (TOPSOIL & ROOT MAT) | | | |
| 2 | | 1.0'-3.0': BROWN/TAN/GRAY SILT w/ TRACE WOOD, GLASS, GRAVEL, & ZONES OF STIFF BROWN CLAY. (FILL), MOIST | | | PP. 0.5-1.5 IN SILT 1.5-2.5 IN CLAY ZONES |
| 3 | | | | | |
| 4 | | 3.0'-9.5' BANDED SANDY GRAY & BROWN SILT, 1"-2" BANDS, MOIST | | | PP. 0.5-2.5 SOFTER NEAR G.W. |
| 5 | | | | | |
| 6 | | | | | |
| 7 | | | | | |
| 8 | | | | | |
| 9 | | | | | |
| 10 | | 9.5'-10.5': BROWN/TAN/WHITE C-F SAND & M-F GRAVEL (ROUNDED), WET | | | HOLE FLOODED UPON REACHING SAND/GRAVEL |
| 11 | | BOTTOM OF PIT @ 10.5' | | | |

GENERAL REMARKS

TEST PIT NO. TP-2