

COMMONWEALTH OF PENNSYLVANIA
PENNSYLVANIA GAME COMMISSION

December 19, 2022

ADDENDUM NO. 1

SOLICITATION NO. 6100057419
PROJECT: PGC-HQ-22-01
Property Line Fencing Contract
OPENING DATE/TIME: December 22, 2022 2:00 PM

This Addendum is hereby made a part of Solicitation No. 6100057419. Please note the changes, information, and instructions contained herein and prepare and submit Bids accordingly.

Bids will still be received and opened on the date and time as stated in the Solicitation.

Addendum No. 1 summary of changes, information, and instructions:

1. Please note: the bid date of December 22nd, 2022 will not change.
2. Revise Project Specification:

TECHNICAL SPECIFICATION NO. 1 - CHAIN LINK FENCE


The following specification section of "1.4 Procedure" is to be revised and read interpreted as below:

1.4 - PROCEDURE

A – Placing Fence – Identify post locations. Auger footing holes (9-inch-diameter for line posts and terminal posts). The depth of holes for line posts is 24-inches. The depth of holes for terminal posts is 36-inches. Set posts, centered and plumb, on the bottom of the holes. Place and tamp backfill. Use 50% earth backfill and 50% concrete backfill for line posts and full depth concrete backfill for terminal posts. Crown the finished surface to shed water.

3. Revise Project Drawings
Drawing No. 2 Correction "Overall Layout" –
Revise Narrative Notes 2 and 3
A. Switch Note Narrative 2 and 3 –

The narrative for Note 2 should be denoted for Note 3, similarly, the narrative for Note 3.

- NOTES**
- NOTE 1 630' LF OF 5' HIGH BLACK CHAIN LINK FENCE, 2" X 9 GA, ON VINYL COATED FRAME WORK. INCLUDES TOP RAIL AND BOTTOM TENSION WIRE.
- NOTE 2 130' LF OF 6' HIGH TONGUE AND GROOVE STYLE PRIVACY PVC FENCE (TAN IN COLOR), 5" X 5" SQUARE POSTS SET IN CONCRETE. CONTRACTOR MUST PROVIDE TWO ADDITIONAL FENCE PANELS AS A BETWEEN POST DAMAGE REPLACEMENTS.
- NOTE 3 286 LF OF 8' HIGH TONGUE AND GROOVE STYLE PRIVACY PVC FENCE (TAN IN COLOR), 5" X 5" SQUARE POSTS SET IN CONCRETE, CONTRACTOR MUST PROVIDE TWO ADDITIONAL FENCE PANELS AS A BETWEEN POST DAMAGE REPLACEMENTS.
- *EXACT PLACEMENT OF THE FENCE TO BE DELINEATED BY THE PGC REPRESENTATIVES TO REMAIN A MINIMUM OF 1' FROM PROPERTY LINE.
* PGC TO PROVIDE PROPERTY LINE SURVEY TO SHOW EXACT LOCATION OF PARCEL BOUNDARY.
*CONTRACTOR TO BE RESPONSIBLE FOR DAMAGE TO PGC PROPERTY.
- 

Any questions concerning this Bid should be directed to PGC Contracts and Procurements Division at 717-787-6594.

Thank you,

Derek Deibler, Purchasing Agent
Contracts and Procurement Division
Bureau of Administrative Services