

**COMMONWEALTH OF PENNSYLVANIA
PENNSYLVANIA GAME COMMISSION**

December 12, 2023

ADDENDUM NO. 1

SOLICITATION NO. 6100059972, 6100059973, 6100059994

PROJECT: PGC-165-23-01
GENERAL CONSTRUCTION CONTRACT- No.1
PLUMBING CONSTRUCTION CONTRACT- No.3
ELECTRICAL CONSTRUCTION CONTRACT-No.4

OPENING DATE/TIME: December 21 2:00 PM

This Addendum is hereby made a part of Solicitation No. 6100059972, 6100059973, 6100059994. Please note the changes, information, and instructions contained herein and prepare and submit Bids accordingly.

Bids will still be received and opened on the date and time as stated in the Solicitation.

Addendum No. 1 summary of changes, information, and instructions:

General Construction Contract No. 1

- 1.** Clarification regarding the scope of work and drawing CS-1. The General Contractor is responsible for all work associated with the installation of the new septic system in accordance with Specifications Section No. 21-Septic Systems -21.1-Scope. Please note that this scope of work begins from the exterior sanitary line cleanout location which is located approximately 5' from the exterior of the building. All other interior underground sanitary work and exterior clean installation is part of Plumbing Contract No.3
- 2.** Clarification regarding scope of work all underground excavation, backfilling and conduit for electrical service, voice and data service and electrical feed to the new fuel tank location will be part of the Electrical Contract No.1

December 12, 2023

SOLICITATION NO. 6100059972, 6100059973, 6100059994

WHM - PGC-165-23-01

ADDENDUM NO. 1

Page 2 of 2

Plumbing Construction Contract No. 3

1. Clarification regarding the scope of work and drawing CS-1. The Plumbing Contract work includes all interior underground sanitary work and extension of the sanitary line 5' from the exterior of the building to the exterior cleanout location as indicated on the plans. The extension of the sanitary line to the new septic tank and installation is part of the General Contract No.1.
2. The scope of work associated with the installation of the sleeve for the new water service in the Mechanical Room slab is part of the General Contract No.1 work as indicated on drawing P-1.

Electrical Construction Contract No. 4

1. Clarification regarding the scope of work, all underground excavation, backfilling and conduit for electrical service, voice and data service and electrical feed to the new fuel tank location will be part of the Electrical Contract No.4. The Bid Line Item #5 of the Bid Form has been revised to reflect this scope of work specifically the Schedule 40 1 ¼" PVC Conduit for underground voice and data service and electrical feed to new fuel tank which now includes 125'linear feet of conduit and (4) total sweeps.

Any questions concerning this Bid should be directed to PGC Contracts and Procurements Division at 717-787-6594.

Thank you,

Derek Deibler, Zachary Barrick and Steve Walthius Purchasing Agent
Contracts and Procurement Division
Bureau of Administrative Services