ATTACHMENT A

Signed Acknowledgement of DCNR DSA Specifications

- 1. The Contractor must choose the appropriate acknowledgement letter:
 - a. DSA Contractor Acknowledgement of DSA Specifications (A.1)

This form is used when the Contractor will be creating and supplying the DSA.

b. **DSA Quarry Letter of Intent (A.2)**

This form is used when the DSA will be created and supplied by a quarry *not owned* by the Contractor.

- 2. The appropriate form must be printed, completed in its entirety, signed, and dated.
 - a. Both A.1 and A.2 *must be signed only* by approved representatives of the Contractor and Quarry respectively.
 - b. The authorized representative must include their title with their signature.
 - c. Representatives must be knowledgeable of DSA and be prepared to answer all questions on the product.
- 3. The Contractor must then include the appropriate fully executed form with their bid response (either A.1 or A.2.).
 - DO NOT attach both acknowledgements.
- 4. Failure to comply with this requirement could result in a non-responsive determination and subsequent disqualification for the Contractor.



BUREAU OF ADMINISTRATIVE SERVICES

CONTRACTOR ACKNOWLEDGEMENT OF DSA PRODUCT

Solicitation # 6100060664 FD12 - Tiadaghton Robbins Run Road Approximate Tonnage – 3,920 (Tonnage is estimated and can increase or decrease based on the needs of the Department.)

	Passive Sieve	Low Percentage	High Percentage	
that meets the following specifi	cations.			
competently create and supply	certified Drivir	ng Surface Aggre	gate (DSA) for t	the Solicitation listed above
confirms that			(Name of	f Contractor) has the ability to
authorized representative of _				(Name of Contractor)
By signing this acknowledgeme	ent I,			(Print Name), an

Passive Sieve	Low Percentage	High Percentage	
1 ½ inch	100%		
¾ inch	65%	97%	
#4	30%	65%	
#16	15%	30%	
#200*	11%	15%	

The fines passing the #200 sieve must be rock material. No clay or silt soil may be added. Limestone material passing the #200 sieve may be used to make up a deficit in the distribution of sandstone aggregate rock, and vice versa. All added material passing the #200 sieve must be derived from rock material that conforms to program specifications. The amount of particles passing the #200 sieve will be determined using the washing procedures specified in PTM No. 100.

*If the Plasticity Index for the Material is 2 or below, then the #200 sieve is permitted to be 11-17%.

pH: 6 - 12.45 as measured by EPA 9045C

LA Abrasion: < 45% loss based on Los Angeles Abrasion test, AASHTO T-96 [ASTM C 131]

Plasticity Index: ≤ 4 based on ASTM D4318 – Standard Test Method for Liquid Limit, Plastic Limit, and Plasticity Index of Soils.

Optimum Moisture: Material will be delivered and placed at optimum moisture content, or up to 2% below ned

that value, as determined for that particular source. The optir using Proctor Test ASTM D698, procedure C, Standard.	num percentage moisture will be determi
Signature of Authorized Representative	Date



BUREAU OF ADMINISTRATIVE SERVICES

QUARRY ACKNOWLEDGEMENT OF DSA PRODUCT - LETTER OF INTENT

Solicitation # 6100060664
FD12 - Tiadaghton
Robbins Run Road
Approximate Tonnage – 3,920
(Tonnage is estimated and can increase or decrease based on the needs of the Department.)

By signing this Letter of Intent I, _____ (Print Name), an

authorized representative of				(Name of Company),
confirms that			(Locatio	n or Name of Quarry) has the
ability to competently create and	d supply to			(Name of
Contractor) certified Driving Sur	face Aggrega	te (DSA) for the	Solicitation liste	ed above that meets the
following specifications.	Passive Sieve	Low Percentage	High Percentage	7
Ī	1 ½ inch	100%		7
	¾ inch	65%	97%	
	#4	30%	65%	
	#16	15%	30%	
L	#200*	11%	15%	
rock, and vice versa. All added conforms to program specification using the washing procedures s *If the Plasticity Index for the Ma	ons. The amo pecified in PT	ount of particles p M No. 100.	passing the #20	00 sieve will be determined
pH: 6 – 12.45 as measured by		,		
LA Abrasion: < 45% loss based	l on Los Ange	les Abrasion tes	t, AASHTO T-9	96 [ASTM C 131]
Plasticity Index: ≤ 4 based on A Plasticity Index of Soils.	ASTM D4318 -	- Standard Test	Method for Liq	uid Limit, Plastic Limit, and
Optimum Moisture: Material will that value, as determined for the using Proctor Test ASTM D698,	at particular so	ource. The optim		
Signature of Authorized Represe	entative		Date	