



Date:	03/12/2020
Subject:	District Landscaping project
Solicitation:	6100050122
Due Date/Time:	03/20/2020 @ 10:00AM
Addendum Number:	1

To All Suppliers:

The Commonwealth of Pennsylvania defines a solicitation "Addendum" as an addition to or amendment of the original terms, conditions, specifications, or instructions of a procurement solicitation (e.g., Invitation for Bids or Request for Proposals), including but not limited to questions and answers, which are considered a material part of the solicitation.

Please see the following update:

Addendum **1** does the following:

1. **Q:** Plan is not to scale?
A: No, it is not. However, the measurements on Plan 1 are accurate.
2. **Q:** Specifications indicate brick color needs to match adjacent building?
A: Brick color needs to match the east end side of the building's existing window trim color. (The group viewed the existing window trim during walk through.)
Reminder that vendor will need to supply brick color sample for approval by Project Manager, prior to construction.
3. **Q:** Is the wall split face retaining or CMU wall?
A: Split face retaining
4. **Q:** Regarding edging, where there is a mechanical edge already there – aka curbing, sidewalk, etc., edging is not needed, correct?
A: That is correct.
5. **Q:** Edging around flag pole and entrance sign?
A: Yes
6. **Q:** Specifications state work must be completed by June 30, 2020. If coronavirus affects building closures, material availability, etc, will there be flexibility with meeting that deadline?
A: Yes, if there are circumstances beyond the control of the department and vendor that impact scheduling, etc. they will be handled accordingly.

Regards,

A handwritten signature in dark ink, appearing to read "Deborah M. Smith", with a long horizontal flourish extending to the right.

Deborah Smith | Purchasing Agent

PA Department of Transportation | Engineering District 3-0

PO Box 218 | 715 Jordan Ave | Montoursville PA 17754

Phone: 570.368.4211 | Fax: 570.368.4411

demsmit@pa.gov