

SOLICITATION ADDENDUM

Date: **03/11/2024**
Subject: **Little Buffalo State Park – Water Supply Questions**
Questions/Answers regarding
Solicitation Number: **6100060509**
Due Date/Time: **03/13/2024 – 10:00 AM**
Addendum Number: **4**

To All Suppliers:

The Commonwealth of Pennsylvania defines a solicitation “Addendum” as an addition to or amendment of the original terms, conditions, specifications, or instructions of a procurement solicitation (e.g., Invitation for Bids or Request for Proposals).

List any and all changes:

This addendum is to clarify questions asked by perspective bidder(s) of this solicitation.
Answers are **bolded in red.**

Question #1: Can PEX Pipe be used to connect to the vendor’s water-box? **Answer: Little Buffalo State Park will provide a 1" PEX waterline to connect to the vendor’s fitting at the "water-box".**

NOTE: NO change to solicitation end date.

Type of Solicitation: Electronic Bid (SRM) - Review the Questions section of your solicitation response to ensure you have responded, as required, to any questions relevant to solicitation addenda issued subsequent to the initial advertisement of the solicitation opportunity.

Except as clarified and amended by this Addendum, the terms, conditions, specifications, and instructions of the solicitation and any previous solicitation addenda, remain as originally written.

Respectfully,

Name: Jody Russell, Procurement Specialist
Phone: 717.783.2566
Email: jorussell@pa.gov