

SOLICITATION ADDENDUM

Date: **03/05/2024**
 Subject: **Little Buffalo State Park – Water Supply Questions**
Questions/Answers Size of Tank & Historical Water Use
 Solicitation Number: **6100060509**
 Due Date/Time: **03/13/2024 – 10:00 AM**
 Addendum Number: **3**

To All Suppliers:

The Commonwealth of Pennsylvania defines a solicitation “Addendum” as an addition to or amendment of the original terms, conditions, specifications, or instructions of a procurement solicitation (e.g., Invitation for Bids or Request for Proposals).

List any and all changes:

This addendum is to further clarify the required tank size and historical water usage of the park.

QUESTION: What capacity is the tank required to hold

ANSWER: The tank is required to hold a 5 - 10,000-gallon capacity.

NOTE: The Statement of work has been updated.

QUESTION: Historical usage of water at the campground. Answer: See charts for 2023, 2022, and 2021 below.

†

Well House #3			
2023			
Month	Total Gallons	Avg. GPD	High
January			
February			
March	523	16.9	442
April	18997	633	1427
May	18219	587	1521
June	23008	767	1604
July	32196	1038	2249
August	42636	1375	3016
September	19166	639	1887
October	18249	589	1437
November			
December			

2022			
Month	Total Gallons	Avg. GPD	High
January			
February			
March	3356	108.26	1896
April	18720	624	2993
May	15476	499.23	1471
June	26401	880.03	2676
July	34024	1097.55	2543
August	26993	870.74	1698
September	23690	789.67	1502
October	11236	362.45	1190
November			
December			

2021			
Month	Total Gallons	Avg. GPD	High
January			
February			
March	3354	108	883
April	15254	508	3478
May	20675	667	3476
June	24825	828	2354
July	30004	968	3837
August	32211	1039	2743
September	27552	918	3078
October	13777	444	4272
November			
December			

NOTE: The solicitation due date HAS NOT CHANGED, still on 03/15/2024 @ 10:00 AM.

Type of Solicitation: Electronic Bid (SRM) - Review the Questions section of your solicitation response to ensure you have responded, as required, to any questions relevant to solicitation addenda issued subsequent to the initial advertisement of the solicitation opportunity.

Except as clarified and amended by this Addendum, the terms, conditions, specifications, and instructions of the solicitation and any previous solicitation addenda, remain as originally written.

Respectfully,

Name: Jody Russell, Procurement Specialist

Phone: 717-783-2556 – Email: jorussell@pa.gov